

**ARSENIC REDUCTION PROJECT
Project Definition**


Northside Water Services Ltd.

File No. 381-13

June 2016

Revised September 2nd, 2016

Thinking beyond.



REVISED SEPTEMBER 2nd, 2016

TABLE OF CONTENTS

1.0	INTRODUCTION.....	2
2.0	STATEMENT OF NEED.....	3
3.0	AVAILABLE WATER TREATMENT TECHNOLOGIES	4
4.0	ITEMS OF WORK.....	5
5.0	CLOSURE.....	8

ATTACHMENTS

Capital Cost Estimate for Private Water Utilities in British Columbia

Standard Depreciation Rates for Private Water Utilities in British Columbia



1.0 INTRODUCTION

Northside Water Services Ltd. (Northside) intends to install new water treatment equipment at their existing well, reservoir and pumphouse facility in Vanderhoof, BC in the 2016 calendar year. The new equipment is intended to reduce arsenic concentrations in the potable water they deliver to their customers to a level that complies with current and anticipated future water quality guidelines. The equipment will provide a secondary benefit by reducing the concentration of manganese in the water, improving the water's taste and appearance.

Northside has retained Scouten Engineering (Scouten) to assist with the coordination and delivery of the project, including making application to the relevant authorities and approval agencies on Northside's behalf. This document is intended to provide an overview of the arsenic reduction project for the benefit of those authorities and agencies.

2.0 STATEMENT OF NEED

Potable water, whether delivered by a public or private utility, must meet the express requirements of the guidance document entitled '*Guidelines for Canadian Drinking Water Quality*', published by Health Canada. That document currently specifies a Maximum Acceptable Concentration (MAC) for arsenic of 10 µg/l, with the additional requirement that the arsenic concentration should be reduced further to a level '*as low as reasonably achievable*' (ALARA), consistent with the efficacy of available water treatment technology and the individual water utility's financial constraints.

Health Canada has signalled that water quality guidelines will be amended in the near future such that the MAC of arsenic in potable water will be reduced to 2 µg/l. This is consistent with trends in other jurisdictions where the MAC of arsenic in potable water has been reduced incrementally over the last two decades. Both the US Environmental Protection Agency (EPA) and the World Health Organization (WHO) have made relatively recent downward adjustments to the MAC of arsenic and are continuing to investigate the health risks associated with any measurable concentration.

Recent water quality tests conducted on samples from Northside's water utility have indicated arsenic concentrations on the order of 11 µg/l, with some seasonal variation reflecting hydrogeological movements in the source aquifer. In short, potable water delivered by Northside does not explicitly meet the current water quality guidelines published by Health Canada and falls well short of the anticipated new and more restrictive requirements of that national agency.

Manganese levels in the potable water delivered by Northside are generally on the order of 200 µg/l, well in excess of the aesthetic objective of 50 µg/l recommended by the water quality guidelines published by Health Canada. While the concentration of manganese has aesthetic implications only (with respect to the odour and taste of the water and its tendency to stain laundry and laundry appliances) Northside recognizes the value that reducing manganese concentrations would bring to its customers.

A number of water treatment technologies have proven to be very effective in reducing the concentration of arsenic in raw or chlorinated water and most of those technologies provide the additional benefit of reducing the concentration of manganese. Northside investigated the feasibility of two such technologies, with the goal of having suitable water treatment installed and fully commissioned in 2017.

3.0 AVAILABLE WATER TREATMENT TECHNOLOGIES

Northside investigated the feasibility of using the following two water treatment technologies to reduce the concentration of arsenic in their delivered water to a level less than to 2 µg/l:

1. Adsorption using purpose-made contact tanks, pressure sand filtration and adsorption media equipment, as supplied by Tiger Filtration Systems
2. Oxidation and filtration using introduced ferric chloride and iron and manganese (greensand) filtration media equipment as supplied by Culligan International

The initial capital cost of the adsorption system, as quoted by Tiger Filtration Systems, was approximately 80% of the initial capital cost of the oxidation and greensand filtration system, as quoted by Culligan. The oxidation and greensand filtration system has significantly lower operating and maintenance costs, however, and the decision was made to pursue this option as having the lowest net present value.

Bench (pilot) testing was done by Culligan on representative raw water samples taken from the Northside facility. That testing indicated that the proposed oxidation and greensand filtration method is capable of reliably lowering the concentrations of both arsenic and manganese in this case to < 2 µg/l.

The full-scale equipment to be installed at Northside's facility in Vanderhoof will be capable of treating 240 US gallons per minute with a triplex, auto-back-washing greensand filtration system.

4.0 ITEMS OF WORK

The following specific items of work have been identified in connection with this project:

Capital (hard) costs

- The supply of a packaged oxidation and greensand filtration plant, complete with filtration media, FOB Vanderhoof, BC.

The treatment equipment will arrive 'skid-mounted', complete with filtration tanks, manifold piping, gauges, controls, etc. The various skids will be suitable for installation on cast-in-place concrete housekeeping pads with appropriate anchor bolts and other attachments.

- The construction of a 30' x 60' wood-framed building.

The new building will house the water treatment equipment and will provide storage area for filtration media, chemicals, etc. With space limited on the existing Northside site the building will be constructed on the footprint of an existing 'Quonset-style' building on the property. The existing foundations are suitable for use with the new structure, resulting in a net cost saving to the project.

- The supply and installation of interface piping.

The new water treatment equipment will be connected to the existing well and reservoir facilities with new buried piping, supplied and installed in accordance with the applicable American Water Works Association (AWWA) and Canadian Standards Association (CSA) requirements.

- The supply and installation of a new electrical service.

The new water treatment equipment will require an expanded electrical service to feed the pumps, motors and additional lighting required. The additional power required to operate the arsenic removal equipment will represent an ongoing additional annual cost to the Northside utility.

Soft costs

- The demolition and disposal of the existing 'Quonset-style' structure.

The existing 'Quonset-style' structure on the Northside site is unsuitable for use to contain the new water treatment equipment and associated media and chemicals. The existing building is not insulated and its sloping walls would interfere with the installation and operation of the new equipment.

- The installation and commissioning of the packaged oxidation and greensand filtration plant.

The new water treatment equipment will be installed and fully commissioned by the equipment supplier (Culligan). Culligan will also provide training to one or more Northside operators on the use and maintenance of the new equipment.

- Water sampling and testing.

Upon commissioning of the new water treatment equipment samples of both raw and treated water will be taken for the purposes of testing to ensure full compliance with the drinking water guidelines published by Health Canada. Testing will be done on an increased frequency after commissioning to confirm the efficacy of the new system through its full range of operation.

- The preparation of detailed drawings and specifications.

Because the water treatment technology is largely proprietary the preparation of final detailed drawings and specifications for the interface piping, valves, external controls, etc. will occur after the purchase of the equipment. At that time Culligan will supply shop drawings indicating the battery limits of their scope, connection requirements, etc.

- Community consultation.

Appropriate documents notifying Northside's customers of the project will be prepared and distributed in a format acceptable to the Deputy Comptroller of Water Rights and in accordance with the Water Utility Act and the Utilities Commission Act. Those documents will be posted on Northside's website and will be circulated in local and regional newspapers (the Omineca Express and the Prince George Citizen).

- The preparation and submittal of project close-out documents.

Record drawings confirming the configuration and location of all equipment and piping 'as-installed' will be prepared under the seal of a BC-registered professional engineer and submitted to the appropriate authority. Photographs and written records taken during the installation of the new equipment and accessories will also be provided.

Copies of the documents '*Capital Cost Estimate for Private Water Utilities in British Columbia*' and '*Standard Depreciation Rates for Private Water Utilities in British*

Columbia' are attached to this report. These documents indicate that the total capital cost of the project, including engineering and a contingency allowance (@15%), is estimated to be **\$448,000**.

An increase in annual operating costs associated with the new arsenic reduction equipment is estimated to be approximately **\$110,000, including additional costs associated with increased contributions to the Replacement Reserve Trust Fund and loan financing**. This increase is associated with routine operation and maintenance costs, the cost of additional insurance required, additional hydro consumption, the cost of chemicals and the cost of additional operator time and training. The increase in annual operating costs also reflects a 1% tax payable to the District of Vanderhoof.

5.0 CLOSURE

Northside Water Services Ltd. intends to install new water treatment equipment in 2016 for the purposes of reducing the concentration of arsenic in the water they deliver to their customers to a level of less than 2 µg/l. The equipment will provide a secondary benefit by reducing the concentration of manganese in the water to a level well below the aesthetic objective (AO) of 50 µg/l, as published by Health Canada in their guidance document entitled '*Guidelines for Canadian Drinking Water Quality*'.

Prepared by:



SCOUTEN ENGINEERING

Dave Scouten P. Eng. – Principal
dscouten@scoutenengineering.com



Appendix 6
Capital Cost Estimate for Private Water Utilities in British Columbia

NARUC Acct No.	Account Title	Estimated Costs ¹	Actual Costs ²
		[\$]	[\$]
A	Source of Supply Plant		
	304 Structures and Improvements		
	304.1 Wood Frame	N/A	
	304.2 Steel	N/A	
	304.3 Cement Block	N/A	
	304.4 Reinforced Concrete or Brick	N/A	
	304.5 Miscellaneous (Electrical Service)	N/A	
	305 Collecting and Impounding Reservoirs		
	305.1 Wood Structures	N/A	
	305.2 Earth Fill Structures	N/A	
	305.3 Concrete Structures	N/A	
	306 Lake, River and Other Intakes		
	306.1 Wood Structures	N/A	
	306.2 Concrete Structures	N/A	
	307 Wells and Springs	N/A	
	309 Supply Mains	N/A	
	309.1 PVC AWWA C900	N/A	
	309.2 HDPE AWWA C906	N/A	
	309.3 Ductile/Cast Iron	N/A	
	309.4 Steel, Cement Lined	N/A	
	309.5 Concrete	N/A	
	309.6 Sub-Marine Mains	N/A	
	339 Other Misc. Water Source Plant	N/A	
B	Pumping Plant		
	304 Structures and Improvements		
	304.1 Wood Frame	N/A	
	304.2 Steel	N/A	
	304.3 Cement Block	N/A	
	304.4 Reinforced Concrete or Brick	N/A	
	304.5 Miscellaneous	N/A	
	310 Power Generation Equipment	N/A	
	311 Pumping Equipment		
	311.1 Electric Pumping Equipment	N/A	
	311.2 Diesel Pumping Equipment	N/A	
	311.3 Other Pumping Equipment	N/A	
	339 Other Miscellaneous Pumping Plant	N/A	
C	Water Treatment Plant		
	304 Structures and Improvements		
	304.1 Wood Frame	\$109,000	
	304.1a Demolition and Disposal	\$5,000	
	304.2 Steel	N/A	
	304.3 Cement Block	N/A	
	304.4 Reinforced Concrete or Brick	N/A	
	304.5 Miscellaneous (Electrical Service)	20,000	
	320 Treatment Equipment		
	320.1 Sand & Other Media Filtration Equipment	\$226,000	
	320.2 Membrane Filtration Equipment	N/A	
	320.3 Chlorination	N/A	
	320.4 Other Water Treatment Equipment	N/A	
	339 Other Miscellaneous Treatment Plant	N/A	
D	Transmission and Distribution Plant		
	304 Structures and Improvements		
	304.1 Wood Frame	N/A	
	304.2 Steel	N/A	
	304.3 Cement Block	N/A	
	304.4 Reinforced Concrete or Brick	N/A	
	304.5 Miscellaneous	N/A	
	330 Distribution Reservoirs		
	330.1 Concrete (underground)	N/A	
	330.2 Steel (above ground)	N/A	

Continued on next page...

Appendix 6
Capital Cost Estimate for Private Water Utilities in British Columbia

NARUC Acct No.	Account Title	Estimated Costs ¹	Actual Costs ²
		[\$]	[\$]
D	Transm. and Distribution Plant (con't)		
	331 Transmission and Distribution Mains		
	331.1 PVC AWWA C900	8,000	
	331.2 HDPE AWWA C906	N/A	
	331.3 Ductile/Cast Iron	N/A	
	331.4 Steel, Cement Lined	N/A	
	331.5 Concrete	N/A	
	331.6 Sub-Marine Mains	N/A	
	333 Services	N/A	
	334 Meters and Meter Installations	N/A	
	335 Hydrants / Standpipes	N/A	
	339 Other Transm. and Distribution Plant	N/A	
E	General Plant		
	304 Structures and Improvements		
	304.1 Wood Frame	N/A	
	304.2 Steel	N/A	
	304.3 Cement Block	N/A	
	304.4 Reinforced Concrete or Brick	N/A	
	304.5 Miscellaneous	N/A	
	340 Office Furniture and Equipment	N/A	
	349 Computer Equipment	N/A	
	341 Transportation Equipment	N/A	
	342 Stores Equipment	N/A	
	343 Tools, Shop and Garage Equipment	N/A	
	344 Laboratory Equipment	N/A	
	345 Power Operated Equipment	N/A	
	346 Communication Equipment		
	346.1 Communication Equipment - SCADA	N/A	
	346.2 Other Communication Equipment	N/A	
	347 Miscellaneous Equipment	N/A	
F	Other Tangible Plant		
	348 Other Tangible Plant³	N/A	
G	Intangible Plant		
	301 Organization		
	302 Franchises and Consents		
Subtotal Construction Cost [\$]		\$368,000	...
Land and Land Rights Cost [\$]	
Engineering Cost⁴		\$25,000	...
Contingency⁵ (@ 15% of Subtotal Construction Cost)		\$55,000	n/a
TOTAL CAPITAL COST		\$448,000	...

Notes:

- ¹ Estimated Costs at CPCN application/pre-construction stage, in CAD \$
- ² Actual Costs at As-Built approval/post construction stage, in CAD \$
- ³ List any applicable items such as Valve Chambers, PRV Stations etc.
- ⁴ Total engineering fees including survey cost, if not specified - by default 10% of Construction Cost (CC)
- ⁵ Contingency allowance at CPCN application/pre-construction stage, if not specified - by default 15% of CC

Schedule A

Standard Depreciation Rates for Private Water Utilities in British Columbia

NARUC		Prescribed Service Life	Prescribed Depreciation Rate	Estimated Costs	Annual Depreciation	Actual Costs	Annual Depreciation
Acct No.	Account Title	SL	DR = 100/SL	EC	AD = EC*DR/100	AC	AD = AC*DR/100
A		[Years]	[% per Year]	[\$]	[\$]	[\$]	[\$]
	Source of Supply Plant						
	304 Structures and Improvements						
	304.1 Wood Frame	30	3.3%	N/A	N/A		
	304.2 Steel	40	2.5%	N/A	N/A		
	304.3 Cement Block	40	2.5%	N/A	N/A		
	304.4 Reinforced Concrete or Brick	50	2.0%	N/A	N/A		
	304.5 Miscellaneous	25	4.0%	N/A	N/A		
	305 Collecting and Impounding Reservoirs						
	305.1 Wood Structures	35	2.9%	N/A	N/A		
	305.2 Earth Fill Structures	60	1.7%	N/A	N/A		
	305.3 Concrete Structures	75	1.3%	N/A	N/A		
	306 Lake, River and Other Intakes						
	306.1 Wood Structures	35	2.9%	N/A	N/A		
	306.2 Concrete Structures	60	1.7%	N/A	N/A		
	307 Wells and Springs	40	2.5%	N/A	N/A		
	309 Supply Mains						
	309.1 PVC AWWA C900	75	1.3%	N/A	N/A		
	309.2 HDPE AWWA C906	75	1.3%	N/A	N/A		
	309.3 Ductile/Cast Iron	60	1.7%	N/A	N/A		
	309.4 Steel, Cement Lined	50	2.0%	N/A	N/A		
	309.5 Concrete	50	2.0%	N/A	N/A		
	309.6 Sub-Marine Mains	20	5.0%	N/A	N/A		
	339 Other Misc. Water Source Plant	25	4.0%	N/A	N/A		
B	Pumping Plant						
	304 Structures and Improvements						
	304.1 Wood Frame	30	3.3%	N/A	N/A		
	304.2 Steel	40	2.5%	N/A	N/A		
	304.3 Cement Block	40	2.5%	N/A	N/A		
	304.4 Reinforced Concrete or Brick	50	2.0%	N/A	N/A		
	304.5 Miscellaneous	25	4.0%	N/A	N/A		
	310 Power Generation Equipment	25	4.0%	N/A	N/A		
	311 Pumping Equipment						
	311.1 Electric Pumping Equipment	25	4.0%	N/A	N/A		
	311.2 Diesel Pumping Equipment	25	4.0%	N/A	N/A		
	311.3 Other Pumping Equipment	25	4.0%	N/A	N/A		
	339 Other Miscellaneous Pumping Plant	25	4.0%	N/A	N/A		
C	Water Treatment Plant						
	304 Structures and Improvements						
	304.1 Wood Frame	30	3.3%	\$100,000	\$3,300		
	304.1a Demolition	N/A	N/A	\$5,000	N/A		
	304.2 Steel	40	2.5%	N/A	N/A		
	304.3 Cement Block	40	2.5%	N/A	N/A		
	304.4 Reinforced Concrete or Brick	50	2.0%	N/A	N/A		
	304.5 Miscellaneous (Electrical Service)	25	4.0%	\$20,000	\$800		
	320 Treatment Equipment						
	320.1 Sand & Other Media Filtration Equipment	30	3.3%	\$226,000	\$7,500		
	320.2 Membrane Filtration Equipment	15	6.7%	N/A	N/A		
	320.3 Chlorination	15	6.7%	N/A	N/A		
	320.4 Other Water Treatment Equipment	20	5.0%	N/A	N/A		

Schedule A

Standard Depreciation Rates for Private Water Utilities in British Columbia

NARUC		Prescribed Service Life	Prescribed Depreciation Rate	Estimated Costs	Annual Depreciation	Actual Costs	Annual Depreciation	
Acct No.	Account Title	SL	DR = 100/SL	EC	AD = EC*DR/100	AC	AD = AC*DR/100	
		[Years]	[% per Year]	[\$]	[\$]	[\$]	[\$]	
D	339 Other Miscellaneous Treatment Plant	25	4.0%	N/A	N/A			
	Transm. and Distribution Plant							
	304 Structures and Improvements							
	304.1 Wood Frame	30	3.3%	N/A	N/A			
	304.2 Steel	40	2.5%	N/A	N/A			
	304.3 Cement Block	40	2.5%	N/A	N/A			
	304.4 Reinforced Concrete or Brick	50	2.0%	N/A	N/A			
	304.5 Miscellaneous	25	4.0%	N/A	N/A			
	330 Distribution Reservoirs							
	330.1 Concrete (underground)	60	1.7%	N/A	N/A			
330.2 Steel (above ground)	50	2.0%	N/A	N/A				
D	Transm. and Distr. Plant (con't)							
	331 Transmission and Distribution Mains							
	331.1 PVC AWWA C900	75	1.3%	\$8,000	\$100			
	331.2 HDPE AWWA C906	75	1.3%	N/A	N/A			
	331.3 Ductile/Cast Iron	60	1.7%	N/A	N/A			
	331.4 Steel, Cement Lined	50	2.0%	N/A	N/A			
	331.5 Concrete	50	2.0%	N/A	N/A			
	331.6 Sub-Marine Mains	20	5.0%	N/A	N/A			
	333 Services	50	2.0%	N/A	N/A			
	334 Meters and Meter Installations	25	4.0%	N/A	N/A			
	335 Hydrants / Standpipes	50	2.0%	N/A	N/A			
	339 Other Transm. and Distribution Plant	25	4.0%	N/A	N/A			
	E	General Plant						
304 Structures and Improvements								
304.1 Wood Frame		30	3.3%	N/A	N/A			
304.2 Steel		40	2.5%	N/A	N/A			
304.3 Cement Block		40	2.5%	N/A	N/A			
304.4 Reinforced Concrete or Brick		50	2.0%	N/A	N/A			
304.5 Miscellaneous		25	4.0%	N/A	N/A			
340 Office Furniture and Equipment		20	5.0%	N/A	N/A			
349 Computer Equipment		5	20.0%	N/A	N/A			
341 Transportation Equipment		7	14.3%	N/A	N/A			
342 Stores Equipment		20	5.0%	N/A	N/A			
343 Tools, Shop and Garage Equipment		15	6.7%	N/A	N/A			
344 Laboratory Equipment		15	6.7%	N/A	N/A			
345 Power Operated Equipment		15	6.7%	N/A	N/A			
346 Communication Equipment		10	10.0%					
346.1 Communication Equipment - SCADA		10	10.0%	N/A	N/A			
346.2 Other Communication Equipment		10	10.0%	N/A	N/A			
347 Miscellaneous Equipment		20	5.0%	N/A	N/A			
F		Other Tangible Plant						
		348 Other Tangible Plant	50	2.0%	N/A	N/A		
G	Intangible Plant							
	301 Organization	100	1.0%	N/A	N/A			

Schedule A

Standard Depreciation Rates for Private Water Utilities in British Columbia

NARUC		Prescribed Service Life	Prescribed Depreciation Rate	Estimated Costs	Annual Depreciation	Actual Costs	Annual Depreciation
Acct No.	Account Title	SL	DR = 100/SL	EC	AD = EC*DR/100	AC	AD = AC*DR/100
		[Years]	[% per Year]	[\$]	[\$]	[\$]	[\$]
302	<i>Franchises and Consents</i>	100	1.0%	N/A	N/A		
a	Subtotal Construction Cost [\$]			\$359,000		...	
b	Total Annual Depreciation [\$]				\$11,700		...
c	Composite Depreciation Rate [%], = b / a * 100		3.3				
d	Engineering Cost ⁶			\$25,000		...	
e	Annual Engineering Cost Component [\$] = d * c / 100				\$810		...
f	Contingency ⁷			\$54,000		n/a	
g	Annual Contingency Cost Component [\$] = f * c / 100				\$1,760		n/a
h	Total Annual Cost = Annual RRF⁸ Contribution = b + e + g				\$14,270		...

Notes:

- ¹ Estimated Costs at CPCN application/pre-construction stage, in CAD \$, from CPCN Application Guide - Appendix 6 - Capital Cost Estimate Form
- ² Annual Depreciation based on Estimated Costs at CPCN stage.
- ³ Actual Costs at post-construction approval stage, in CAD \$, from CPCN Application Guide - Appendix 6 - Capital Cost Estimate Form
- ⁴ Annual Depreciation based on Actual Costs at post-construction approval stage; for establishing the final Water Tariff
- ⁵ List any applicable items such as Valve Chambers, PRV Stations etc.
- ⁶ Total engineering fees including survey cost, (see CPCN Application Guide - Appendix 6 - Capital Cost Estimate Form)
- ⁷ Contingency allowance at CPCN application/pre-construction stage, (see CPCN Application Guide - Appendix 6 - Capital Cost Estimate Form)
- ⁸ RRF - Replacement Reserve Fund, equals rows b + e + g